

THE CITY OF NEW YORK
HOUSING AND DEVELOPMENT ADMINISTRATION
DEPARTMENT OF BUILDINGS

DEPARTMENTAL MEMORANDUM

DATE: April 30, 1974

TO: Borough Superintendents

FROM: Thomas V. Burke, P.E., Director of Operations

SUBJECT: INTERPRETATION OF C26-1703.1(k) H-2 OCCUPANCY PATIENTS ROOMS

Section C26-1703.1(k) of the Building Code requires all corridors and exit passageways in H occupancies be sprinklered. In addition, patients rooms in H-2 occupancies require smoke detectors installed in accordance with C26-1703.2. "Such smoke detectors system shall be of the supervisory type connected to an approved central station."

Reference Standard 17-3 (Standards for Installation of Fire Sprinkler, etc., Alarm and Extinguishing Systems) by cross reference provides standards for the installation of smoke detectors - paragraph 13 sub.(n) and (o).


The requirements for installation of smoke detectors in patients rooms of H-2 occupancies may be waived provided the entire building is sprinklered. Sprinkler heads designed to operate at a temperature of 135° F shall be used in patients rooms. These heads shall also be used for other rooms used by patients and shall include sleeping rooms, lounges, lobbies, rehabilitation, recreation, treatment rooms.

continued....

201

-2-

Section C26-1703.1(k) for installation of smoke detectors or a waiver by installation of a sprinkler system shall apply to occupancies used for the care of persons with physical limitations because of health or age; and shall include hospitals, nursing homes, homes for the aged, sanitariums, health related facilities, domicilliary care facilities, proprietary homes for adults, nurseries with overnight facilities.


Thomas V. Burke, P.E.
Director of Operations

TVB/LR/sc

cc: Executive staff