

Report Month & Year	Type of Test	Laboratory Name	Development Name	Building #	Floor	Lab Report ID Number	Type of Location	Location of Sample	Sample Source	Date Sample Collected	Date Sample Analyzed	Copper Concentration (ppm)	Copper Qualifier	Silver Concentration (ppm)	Silver Qualifier
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	1	14		Public	Hallway	Slop Sink	10/26/2022	10/28/2022	0.717		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	1	11		Public	Hallway	Slop Sink	10/26/2022	10/28/2022	0.272		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	1	8		Public	Hallway	Slop Sink	10/26/2022	10/28/2022	<0.050		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	1	Basement		Public	Basement	Hot Water Return	10/26/2022	10/28/2022	14.30	3.E, 5.E	0.152	3.E, 5.E
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	1	Basement		Public	Basement	Hot Water Supply	10/26/2022	10/28/2022	0.461		0.049	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	4	Basement		Public	Basement	Hot Water Return	10/26/2022	10/31/2022	0.055		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	4	Basement		Public	Basement	Hot Water Supply	10/26/2022	10/31/2022	<0.050		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	4	14		Public	Hallway	Slop Sink	10/26/2022	10/31/2022	0.186		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	4	11		Public	Hallway	Slop Sink	10/26/2022	10/31/2022	0.163		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	4	5		Public	Hallway	Slop Sink	10/26/2022	10/31/2022	0.681		0.025	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	6	14		Public	Hallway	Slop Sink	10/26/2022	10/31/2022	0.800		0.015	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	6	5		Public	Hallway	Slop Sink	10/26/2022	10/31/2022	0.198		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	6	Basement		Public	Basement	Hot Water Return	10/26/2022	10/31/2022	0.248		0.017	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	6	Basement		Public	Basement	Hot Water Supply	10/26/2022	10/31/2022	0.069		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	6	11		Apartment	Apt [REDACTED]	Kitchen Sink	10/26/2022	10/31/2022	0.259		0.034	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	7	14		Public	Hallway	Slop Sink	10/26/2022	10/31/2022	0.453		0.043	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	7	8		Public	Hallway	Slop Sink	10/26/2022	10/31/2022	1.314	5.E	0.031	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	7	2		Public	Hallway	Slop Sink	10/26/2022	10/31/2022	0.457		0.035	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	7	Basement		Public	Basement	Hot Water Return	10/26/2022	10/31/2022	0.576		0.042	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	7	Basement		Public	Basement	Hot Water Supply	10/26/2022	10/31/2022	1.066		0.156	5.E
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	9	Basement		Public	Basement	Hot Water Return	10/27/2022	10/31/2022	0.346		0.033	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	9	Basement		Public	Basement	Hot Water Supply	10/27/2022	10/31/2022	0.205		0.016	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	9	14		Public	Hallway	Slop Sink	10/27/2022	10/31/2022	0.259		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	9	11		Public	Hallway	Slop Sink	10/27/2022	10/31/2022	0.224		0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	9	5		Public	Hallway	Slop Sink	10/27/2022	10/31/2022	0.400		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	10	Basement		Public	Basement	Hot Water Return	10/26/2022	10/31/2022	0.151		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	10	Basement		Public	Basement	Hot Water Supply	10/26/2022	10/31/2022	0.126		0.011	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	10	14		Public	Hallway	Slop Sink	10/26/2022	10/31/2022	0.222		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	10	8		Public	Hallway	Slop Sink	10/26/2022	10/31/2022	0.210		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	10	5		Public	Hallway	Slop Sink	10/26/2022	10/31/2022	0.213		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	11	Basement		Public	Basement	Hot Water Return	10/26/2022	10/31/2022	0.113		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	11	Basement		Public	Basement	Hot Water Supply	10/26/2022	10/31/2022	0.054		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	11	14		Apartment	Apt [REDACTED]	Kitchen Sink	10/26/2022	10/31/2022	0.067		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	11	13		Apartment	Apt [REDACTED]	Kitchen Sink	10/26/2022	10/31/2022	0.076		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	11	5		Apartment	Ap [REDACTED]	Kitchen Sink	10/26/2022	10/31/2022	0.052		<0.010	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	13	14		Public	Basement	Kitchen Sink	10/26/2022	10/31/2022	0.908		0.039	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	13	11		Public	Basement	Kitchen Sink	10/26/2022	10/31/2022	0.639		0.028	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	13	8		Apartment	Apt [REDACTED]	Kitchen Sink	10/26/2022	10/31/2022	0.583		0.030	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	13	11		Apartment	Ap [REDACTED]	Kitchen Sink	10/26/2022	10/31/2022	1.407	5.E	0.028	
October 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	13	8		Apartment	Apt [REDACTED]	Kitchen Sink	10/26/2022	10/31/2022	0.649		0.032	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	2	Basement		Public	Basement	Hot Water Return	10/26/2022	11/1/2022	2618	5.E	7.800	5.E

Report Month & Year	Type of Test	Laboratory Name	Development Name	Building #	Floor	Lab Report ID Number	Type of Location	Location of Sample	Sample Source	Date Sample Collected	Date Sample Analyzed	Copper Concentration (ppm)	Copper Qualifier	Silver Concentration (ppm)	Silver Qualifier
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	2	Basement		Public	Basement	Hot Water Supply - Slop Sink	10/26/2022	11/1/2022	0.071		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	2	14		Public	Hallway	Slop Sink	10/26/2022	11/1/2022	1.381	5.E	0.016	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	2	11		Public	Hallway	Slop Sink	10/26/2022	11/1/2022	0.093		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	2	5		Public	Hallway	Slop Sink	10/26/2022	11/1/2022	0.349		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	5	Basement		Public	Basement	Hot Water Return	10/26/2022	11/1/2022	38.30	5.E	3.173	5.E
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	5	Basement		Public	Basement	Hot Water Supply	10/26/2022	11/1/2022	0.342		0.069	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	5	14		Public	Hallway	Slop Sink	10/26/2022	11/1/2022	2.100	5.E	0.084	5.E
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	5	11		Public	Hallway	Slop Sink	10/26/2022	11/1/2022	0.684		0.084	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	5	5		Public	Hallway	Slop Sink	10/26/2022	11/1/2022	0.674		0.095	5.E
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	3	Basement		Public	Basement	Hot Water Return	10/26/2022	11/1/2022	0.217		0.026	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	3	Basement		Public	Basement	Hot Water Supply	10/26/2022	11/1/2022	0.200		0.030	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	3	14		Public	Hallway	Slop Sink	10/26/2022	11/1/2022	6.926	5.E	0.527	5.E
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	3	4		Public	Hallway	Slop Sink	10/26/2022	11/1/2022	1.197		0.045	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	3	5		Public	Hallway	Slop Sink	10/26/2022	11/1/2022	0.708		0.036	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	8	Basement		Public	Basement	Hot Water Return	10/26/2022	11/1/2022	0.177		0.012	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	8	Basement		Public	Basement	Hot Water Supply	10/26/2022	11/1/2022	0.131		0.018	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	8	14		Public	Hallway	Slop Sink	10/26/2022	11/1/2022	3.963	5.E	0.247	5.E
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	8	11		Public	Hallway	Slop Sink	10/26/2022	11/1/2022	2.220	5.E	0.096	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	8	8		Public	Hallway	Slop Sink	10/26/2022	11/1/2022	<0.050		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	12	Basement		Public	Basement	Hot Water Return	10/26/2022	11/1/2022	5.034	5.E	0.031	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	12	Basement		Public	Basement	Hot Water Supply	10/27/2022	11/1/2022	0.322		0.033	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	12	14		Public	Hallway	Slop Sink	10/27/2022	11/1/2022	9.704	5.E	1.050	5.E
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	12	11		Public	Hallway	Slop Sink	10/27/2022	11/1/2022	6.417	5.E	0.170	5.E
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Saint Nicholas	12	5		Public	Hallway	Slop Sink	10/27/2022	11/1/2022	0.502		0.030	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	1	Basement		Public	Basement	Hot Water Return	10/27/2022	11/4/2022	1.669	5.E	0.093	5.E
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	1	Basement		Public	Basement	Hot Water Supply	10/27/2022	11/5/2022	0.134		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	1	10		Apartment	Apt [REDACTED]	Kitchen Sink	10/27/2022	11/6/2022	0.078		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	1	9		Public	Hallway	Slop Sink	10/27/2022	11/7/2022	1.812	5.E	0.06	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	1	6		Public	Hallway	Slop Sink	10/27/2022	11/8/2022	0.388		0.026	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	2	Basement		Public	Basement	Hot Water Return	10/27/2022	11/2/2022	4.918	5.E	0.035	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	2	Basement		Public	Basement	Hot Water Supply	10/27/2022	11/2/2022	0.056		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	2	10		Apartment	Ap [REDACTED]	Kitchen Sink	10/27/2022	11/2/2022	0.072		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	2	9		Public	Hallway	Slop Sink	10/27/2022	11/2/2022	0.572		0.020	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	2	6		Public	Hallway	Slop Sink	10/27/2022	11/2/2022	0.358		0.012	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	3	Basement		Public	Basement	Hot Water Return	10/27/2022	11/4/2022	373	5.E	7.780	5.E
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	3	Basement		Public	Basement	Hot Water Supply	10/27/2022	11/4/2022	<0.050		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	3	10		Apartment	Apt [REDACTED]	Kitchen Sink	10/27/2022	11/4/2022	0.080		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	3	9		Apartment	Apt [REDACTED]	Kitchen Sink	10/27/2022	11/4/2022	0.068		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	3	3		Apartment	Apt [REDACTED]	Kitchen Sink	10/27/2022	11/4/2022	0.058		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	4	Basement		Public	Basement	Hot Water Return	10/27/2022	11/2/2022	0.139		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	4	Basement		Public	Basement	Hot Water Supply	10/27/2022	11/2/2022	0.117		<0.010	

Report Month & Year	Type of Test	Laboratory Name	Development Name	Building #	Floor	Lab Report ID Number	Type of Location	Location of Sample	Sample Source	Date Sample Collected	Date Sample Analyzed	Copper Concentration (ppm)	Copper Qualifier	Silver Concentration (ppm)	Silver Qualifier
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	4	10		Apartment	Apt [REDACTED]	Kitchen Sink	10/27/2022	11/2/2022	0.122		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	4	9		Public	Hallway	Slop Sink	10/27/2022	11/2/2022	0.692		0.034	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	4	3		Public	Hallway	Slop Sink	10/27/2022	11/2/2022	0.064		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	5	Basement		Public	Basement	Hot Water Return	10/27/2022	11/2/2022	0.167		0.020	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	5	Basement		Public	Basement	Hot Water Supply	10/27/2022	11/2/2022	0.117		0.018	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	5	10		Apartment	Apt [REDACTED]	Kitchen Sink	10/27/2022	11/2/2022	0.115		0.017	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	5	9		Public	Hallway	Slop Sink	10/27/2022	11/2/2022	0.157		0.022	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bland	5	3		Public	Hallway	Slop Sink	10/27/2022	11/2/2022	0.127		0.020	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Butler	3	Basement		Public	Basement	Hot Water Return	10/29/2022	11/3/2022	1.376	5.E	0.017	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Butler	3	Basement		Public	Basement	Hot Water Supply	10/29/2022	11/3/2022	0.183		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Butler	3	21		Public	Hallway	Slop Sink Hose	10/29/2022	11/3/2022	<0.050		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Butler	3	20		Public	Hallway	Slop Sink Hose	10/29/2022	11/3/2022	0.118		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Butler	3	10		Public	Hallway	Slop Sink	10/29/2022	11/3/2022	0.067		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bronx River	7	Basement		Public	Basement	Hot Water Supply	10/29/2022	11/3/2022	0.118		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bronx River	7	Basement		Public	Basement	Hot Water Return	10/29/2022	11/3/2022	0.139		0.021	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bronx River	7	1		Public	Hallway	Slop Sink	10/29/2022	11/3/2022	<0.050		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Bronx River	7	7		Public	Hallway	Slop Sink	10/29/2022	11/3/2022	1.032		0.030	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Ft. Independence	1	Basement		Public	Basement	Hot Water Return	10/29/2022	11/3/2022	0.221		0.023	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Ft. Independence	1	Basement		Public	Basement	Hot Water Supply (Kitchen Sink)	10/29/2022	11/3/2022	0.079		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Ft. Independence	1	21		Public	Hallway	Slop Sink Hose	10/29/2022	11/3/2022	0.303		0.012	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Ft. Independence	1	20		Public	Hallway	Slop Sink Hose	10/29/2022	11/3/2022	0.200		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Ft. Independence	1	10		Public	Hallway	Slop Sink Hose	10/29/2022	11/3/2022	0.139		0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Webster	5	Basement		Public	Basement	Hot Water Return	10/29/2022	11/4/2022	2.466	5.E	0.716	5.E
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Webster	5	Basement		Public	Basement	Hot Water Supply (Slop sink)	10/29/2022	11/4/2022	0.555		0.039	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Webster	5	21		Public	Hallway	Slop Sink	10/29/2022	11/4/2022	0.709		0.043	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Webster	5	18		Apartment	Apt [REDACTED]	Kitchen Sink	10/29/2022	11/4/2022	0.522		0.04	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Webster	5	10		Apartment	Ap [REDACTED]	Kitchen Sink	10/29/2022	11/4/2022	0.516		0.041	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Clason Point Gardens	Boiler Plant BLDG 18	Basement		Public	Basement	Hot Water Return	10/29/2022	11/3/2022	0.263		0.022	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Clason Point Gardens	Boiler Plant BLDG 18	Basement		Public	AP [REDACTED]	Hot Water Supply (Kitchen Sink)	10/29/2022	11/3/2022	0.130		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Clason Point Gardens	1	2		Apartment	APT [REDACTED]	Bathroom Sink	10/29/2022	11/3/2022	0.179		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Clason Point Gardens	3	1		Apartment	Apt [REDACTED]	Kitchen Sink	10/29/2022	11/3/2022	0.140		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Clason Point Gardens	30	1		Apartment	APT [REDACTED]	Kitchen Sink	10/29/2022	11/3/2022	0.154		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	1	Basement		Public	Basement	Hot Water Return	10/26/2022	11/2/2022	0.499		0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	1	Basement		Public	Basement	Hot Water Supply	10/26/2022	11/2/2022	<0.050		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	1	21		Public	Hallway	Slop Sink	10/26/2022	11/2/2022	0.093		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	1	20		Public	Hallway	Slop Sink	10/26/2022	11/2/2022	0.062		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	1	10		Public	Hallway	Slop Sink	10/26/2022	11/2/2022	0.060		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	East River Houses	8	Basement		Public	Basement	Hot Water Return	10/31/2022	11/2/2022	0.260		0.040	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	East River Houses	8	1		Apartment	Ap [REDACTED]	Hot Water Supply	10/31/2022	11/2/2022	0.360		0.038	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	East River Houses	8	6		Apartment	Apt [REDACTED]	Kitchen Sink	10/31/2022	11/2/2022	0.299		0.036	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	East River Houses	8	4		Apartment	Ap [REDACTED]	Slop Sink	10/31/2022	11/2/2022	0.222		0.038	

Report Month & Year	Type of Test	Laboratory Name	Development Name	Building #	Floor	Lab Report ID Number	Type of Location	Location of Sample	Sample Source	Date Sample Collected	Date Sample Analyzed	Copper Concentration (ppm)	Copper Qualifier	Silver Concentration (ppm)	Silver Qualifier
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	East River Houses	8	2		Apartment	Apt [REDACTED]	Slop Sink	10/31/2022	11/2/2022	0.317		0.038	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	2	Basement		Public	Basement	Hot Water Return	10/26/2022	11/3/2022	0.103		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	2	Basement		Public	Basement	Hot Water Supply	10/26/2022	11/3/2022	0.492		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	2	21		Public	Hallway	Slop Sink	10/26/2022	11/3/2022	0.072		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	2	20		Public	Hallway	Slop Sink	10/26/2022	11/3/2022	0.109		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	2	11		Public	Hallway	Slop Sink	10/26/2022	11/3/2022	0.068		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	3	Basement		Public	Basement	Hot Water Return	10/26/2022	11/3/2022	0.258		0.056	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	3	Basement		Public	Basement	Hot Water Supply	10/26/2022	11/3/2022	0.155		0.015	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	3	21		Public	Hallway	Slop Sink	10/26/2022	11/3/2022	0.128		0.016	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	3	20		Apartment	Ap [REDACTED]	Slop Sink	10/26/2022	11/3/2022	0.142		0.019	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	3	13		Public	Hallway	Slop Sink	10/26/2022	11/3/2022	0.496		0.027	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	4	Basement		Public	Basement	Hot Water Return	10/26/2022	11/3/2022	13.270		<0.100	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	4	Basement		Public	Basement	Hot Water Supply	10/26/2022	11/3/2022	0.056		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	4	21		Public	Hallway	Slop Sink	10/26/2022	11/3/2022	0.133		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	4	20		Public	Hallway	Slop Sink	10/26/2022	11/3/2022	0.131		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	4	11		Public	Hallway	Slop Sink	10/26/2022	11/3/2022	0.078		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	5	Basement		Public	Basement	Hot Water Return	10/26/2022	11/3/2022	0.076		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	5	Basement		Public	Basement	Hot Water Supply	10/26/2022	11/3/2022	0.129		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	5	19		Public	Hallway	Slop Sink	10/26/2022	11/3/2022	0.089		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	5	20		Public	Hallway	Slop Sink	10/26/2022	11/3/2022	0.074		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Drew Hamilton	5	10		Public	Hallway	Slop Sink	10/26/2022	11/3/2022	0.052		<0.010	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Melrose	2	12		Public	Hallway	Slop Sink	10/29/2022	11/3/2022	2.495	5.E	0.048	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Melrose	2	6		Public	Hallway	Slop Sink	10/29/2022	11/3/2022	3.962	5.E	0.175	5.E
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Melrose	2	1		Public	Hallway	Slop Sink	10/29/2022	11/3/2022	0.901		0.034	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Melrose	2	Basement		Public	Basement	Hot water Supply	10/29/2022	11/3/2022	2.392	5.E	0.047	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Melrose	2	Basement		Public	Basement	Hot Water Return	10/29/2022	11/3/2022	1.950	5.E	0.041	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Melrose	4	1		Public	Hallway	Slop Sink	10/29/2022	11/4/2022	0.088		0.014	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Melrose	4	12		Public	Hallway	Slop Sink	10/29/2022	11/4/2022	2.794	5.E	0.113	5.E
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Melrose	4	6		Public	Hallway	Slop Sink	10/29/2022	11/4/2022	0.291		0.034	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Melrose	4	Basement		Public	Compactor Room	Hot Water Supply	10/29/2022	11/4/2022	0.291		0.034	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Melrose	6	Basement		Public	Basement	Hot Water Return	10/29/2022	11/3/2022	0.249		0.021	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Melrose	6	1		Public	Hallway	Hot water Supply	10/29/2022	11/3/2022	0.646		0.041	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Melrose	6	12		Public	Hallway	Slop Sink	10/29/2022	11/3/2022	0.321		0.041	
November 2022	Copper Silver ICP	Long Island Analytical Laboratories, Inc.	Melrose	6	6		Public	Hallway	Slop Sink	10/29/2022	11/3/2022	0.292		0.025	

Notes

1. Qualifier 5.E indicates level found exceeds the maximum contaminant level (MCL) as set by local, state or federal agencies.
2. Qualifier 3.E indicates compound reported at a dilution factor.